

# SAFETY/RISK/HAZARD ASSESSMENT

## PLANT INFORMATION

NHG Ref/Part No.

Plant ID: TANK2000

Plant Name: Water Tank 2000LT

Operator Competency: Plant Licence Not Required  
*It is the hirer's responsibility to ensure that all operators are competent.*

Please refer to the User Guide and Operators Manual for detailed Operating Instructions



Protective  
equipment  
must be worn  
when operating  
this machine



## RISK ASSESSMENT INFORMATION

### Potential Hazard(s)

#### Injury or death by drowning

Risk Level High

Control Measures Maintain visual contact of children or impaired persons at all times when near any water source. A child can drown in as little as 5-8cm after being submerged for only 30 seconds.

Ensure locking devices are fitted to all access points and are secure.

#### Loss of consciousness, injury or death by entering confined space

Risk Level High

Control Measures Ensure locking devices are fitted to all access points and are secure.

Do not allow persons to enter water tank at any time.

#### Illness from contact with contaminated water

Risk Level High

Control Measures Ensure water path (gutters, pipes, etc.) to tank is clean and clear of debris and contaminants which may cause harm if ingested.

Test water quality regularly and treat where necessary.

**Please refer to the User Guide and Operators Manual  
for detailed Operating Instructions**

*The safety information contained in this assessment is general information only and should not be relied upon as a substitute for professional advice or tuition, which the hirer should seek before operating.*